

**AUDIO VISUAL SYSTEMS FOR JUSTICE CENTER/PUBLIC SAFETY EXPANSION
CATAWBA COUNTY RFP 10-1014
July 14, 2016
ADDENDUM NINE**

Alternate Bid:

In the event the County wishes to interconnect courtrooms to share digital content through the AV systems in a one too many environment using a single standalone AV Network, request each vendor propose networking and any other equipment required to interconnect the courts for this purpose. If routers or switches are proposed please ensure they are adequately sized and manageable via the County's IT Staff. The county currently uses Cisco equipment. (This was referenced in Addendum Three, but we failed to add to the next Addendum.)

Question:

Please provide a list of all spaces that require (ADA) assisted listening systems and include coverage area required and participant (receiver) types and quantities for all (ADA) assisted listening systems.

Response: A total of 20 will be needed the following manufacturer or equivalent will be accepted: Listen Tech- LT-82-01 Listen IR 1-Channel Transmitter; LR-42 IR Stethoscope 4- Channel; LA-140-GY Stationary IR Radiator.

Room numbers:

All Courtrooms: 1043-A2, 2012, 2056, 2060, 2074

Meeting Room 1031A, 1031B

Commissioners' Room 2009

Note:

Please use the attached revised proposal signature page to indicate receipt of Addenda.

Note:

The deadline to ask questions has been extended to 5:00 p.m. Friday, July 15, 2016.

Debbie Anderson
Purchasing Manager

AV CONTRACTOR: _____

ADDRESS: _____

COUNTY, STATE, ZIP: _____

TELEPHONE NUMBER: _____

EMAIL ADDRESS: _____

FEDERAL EMPLOYER IDENTIFICATION NUMBER: _____

Acknowledge receipt of Addenda 1, 2, 3, 4, 5, 6, 7, 8, 9, _____, _____, _____.

SIGNATURE: _____ TITLE: _____

TYPED NAME: _____ DATE: _____

**THIS PAGE MUST BE SIGNED AND INCLUDED IN YOUR PROPOSAL.
UNSIGNED PROPOSALS WILL NOT BE CONSIDERED.**