

Catawba County, North Carolina
Catawba County Blackburn Landfill – Gas Conditioning System Improvements
Bid Number 15-1010

Responses to Questions Received

1. *Electrical Drawing E-4: What are the transformers going to be used for?*

Transformers NT-1 and NT-2 are existing transformers that were not previously identified by name on the drawings. No work is required on these transformers.

2. *Can the conduit to the blower skid be capped off or does it have to be dug up?*

The conduit to the existing blower can be capped off.

3. *Do they really want a 3x3 underground box for the additional treatment skid control panel?*

Yes, provide the pullbox as shown.

