

ADDENDUM NUMBER THREE

Date: June 10, 2013

To: All Bidders

From: **Jenkins•Peer Architects**
Charlotte, NC

Re: Catawba County
Sherrills Ford – Terrell Branch Library
JPA Project #: 11SFL900

NOTICE TO BIDDERS:

Bidder is hereby notified that this Addendum shall hereby become a part of the Contract Documents, and shall be attached to the Project Manual for the Project.

The following items are intended to revise and clarify the Drawings and the Project Manual.

The bidder shall see that his Sub-Bidders are in full receipt of the information contained herein.

GENERAL NOTES:

1. This Addendum includes the following groups and subsequent “items” referring to various parts of the Contract Documents.
2. Where an “item” is “Drawing Sheets reissued,” the sheet is replaced in its entirety with the attached sheets.
3. Where an “item” is “Bulletin Drawings enclosed,” the attached bulletin drawing modifies the sheet referenced in that bulletin drawing’s titleblock.

CORRECTIONS TO PREVIOUS ADDENDA ISSUED: **1**

Correction to Addenda Number Two, Issued June 7, 2013:

Revise Addendum title line and closing footer from “ADDENDUM NUMBER ONE” to “ADDENDUM NUMBER TWO”

DIVISION 00 – PROCUREMENT AND CONTRACTING REQUIREMENTS **(1) ITEMS**

-1- Descriptive Change

PROJECT MANUAL:

SPECIFICATION DIVISIONS **(2) ITEMS**

-2- Descriptive Changes

DRAWINGS:

(T) TITLE, GENERAL, LIFE-SAFETY DRAWINGS (0) ITEMS

(C) CIVIL, PLANTING, & IRRIGATION DRAWINGS (0) ITEMS

(S) STRUCTURAL DRAWINGS (0) ITEMS

(A) ARCHITECTURAL DRAWINGS (0) ITEMS

(FP) FIRE PROTECTION DRAWINGS (0) ITEMS

(P) PLUMBING DRAWINGS (0) ITEMS

(M) MECHANICAL DRAWINGS (0) ITEMS

(E) ELECTRICAL DRAWINGS (0) ITEMS

MISCELLANEOUS:

MISCELLANEOUS DOCUMENTS (0) ITEMS

END OF TITLE PAGE

DIVISION 00 – PROCUREMENT AND CONTRACTING REQUIREMENTS

NEW BID DATE: REVISE FIRST PARAGRAPH OF ADVERTISEMENT TO BID TO READ:

Sealed Bids will be received from pre-qualified bidders on Tuesday, June 18, 2013 at the Catawba County Government Center, 2nd Floor Meeting Room, 100A South West Boulevard, Newton, North Carolina for the construction of the Sherrills Ford Library, located at 9154 Sherrills Ford Road, Terrell, NC 28682. Bids will be received at 2:00 PM at which time and place all bids will be opened and read.

PROJECT MANUAL

1. SPECIFICATIONS SECTION 23 02 52 Refrigerant Piping Insulation

Part 2 – Products

Type P-1 and P-2 Piping Insulation:

Refrigerant Liquid, Suction, refrigerant controllers and piping from outdoor unit to VRF system controller should all read ¾” thickness.

Insulation type shall be Armaflex where insulation is run concealed.

Insulation type shall be molded glass fiber with canvas jacket prepped for painting in all areas where run exposed.

2. SPECIFICATIONS SECTION 23 02 55 Condensate Drain Piping Insulation

Part 2 – Products

Type P-3 Piping Insulation:

Refrigerant controllers and all Air Handler condensate piping insulation should all read ¾” thickness.

Insulation type shall be Armaflex where insulation is run concealed.

Insulation type shall be molded glass fiber with canvas jacket prepped for painting in all areas where run exposed.

END OF ADDENDUM NUMBER THREE