



J. STAN WINSTEAD, AIA

22 NORTH MAIN AVE., P.O. BOX 321  
NEWTON, NORTH CAROLINA 28658

TELEPHONE: (828) 464-2827  
FAX: (828) 464-3229

## ADDENDUM #4

**Catawba County**

**Catawba County EMS Base Station – Hickory, NC**

**Bid Number #25-1015**

Hickory, North Carolina

January 24, 2025

Applying to all bidders.

This addendum is issued for the purpose of clarifying the intent of the contract documents for making necessary corrections, deletions, and/or additions to the documents on all items of discrepancy raised up to the time of the issuance of this addendum.

Each bidder is hereby instructed and authorized to incorporate into his proposal the instructions contained in this addendum.

### TO ALL BIDDERS

1. **Reminder:** A Revised Bid Opening Date: Bid opening date for this project is now being pushed out to February 13, 2025. A mandatory pre-bid conference was held on December 18th, 2024 on the site at 3:00 pm. You must have had a representative of your company there to be eligible to bid this project. The new details are as follows: Catawba County will receive sealed bids for the construction of a new Catawba County EMS Base Station, Bid Number 25-1015, in the 2nd Floor Meeting Room, Government Center, 25 Government Drive, Newton, North Carolina, 28658 until 3:00 PM, local prevailing time, on February 13, 2025. The clock/Apple phone in the Government Center, 2nd Floor Meeting Room will be used to determine bid submission closure. Bids received after 3:00 PM on February 13, 2025, will not be accepted. Immediately thereafter bids shall be publicly opened and read by the Architect for furnishing of labor, materials, and equipment for the construction of the new Catawba County EMS Base Station - Hickory. The project location is 827 E Ave SE, Hickory, North Carolina 28602.
2. **Reminder:** A Revised Due Date for Contractor Questions: Questions regarding the Scope of Work, bid process or bid documents must be delivered in writing to Stan Winstead in the office of the Architect, Post Office Box 321, Newton, North Carolina 28658, Phone (828) 464-2827, Fax (828) 464-3229, Email [winarch@bellsouth.net](mailto:winarch@bellsouth.net) no later than 4:00 PM. Eastern Time, on January 29, 2025. All questions received before the deadline will be addressed in an Addendum. Any questions received after the deadline will not be addressed prior to the Bid Opening. Do not contact the owner with questions.



J. STAN WINSTEAD, AIA

22 NORTH MAIN AVE., P.O. BOX 321  
NEWTON, NORTH CAROLINA 28658

TELEPHONE: (828) 464-2827  
FAX: (828) 464-3229

3. GC is to provide (14) Bollards total for this project. See Civil drawings for detail. (5) bollards will flank the front bay doors, (5) will flank the rear bay doors, and (4) will be located at the dumpster enclosure.
4. For clarification: Specifications call for GC to provide an allowance in the base bid of \$35,000 for materials and labor, (including electrical materials and labor) for a complete Tapco 'EVWS' Emergency Vehicle Warning System. The system shall be complete and functioning properly when finished. Details and notes are in the electrical drawings. The contact information for the Tapco Representative that I have is:

**Jason Decker**

Distributor and Bid Search Manager

Office: (262) 649-5246

Fax: (262) 649-5133

[jason.decker@tapconet.com](mailto:jason.decker@tapconet.com)

[Visit us at TAPCOnet.com](http://www.tapconet.com)

5. GC is to provide in the base bid the monument sign located at the front of the station as shown in the civil drawings. This sign has a concrete footing, a masonry base of block (matches station) and a brick soldier course (matches station) as the upper most course. The sign is to be as shown on the provided drawing by Sign Systems Inc. in Hickory. Included in this package shall be 12 interior room id signs and front and back glass door signage. Contact Sandy Hoyle at 828-322-5622 for pricing. Sign and all signage shall be complete and installed.
6. GC is to provide an approved Knox Box for the building. It shall be installed and mounted in a location approved by a fire official.
7. We have re-submitted drawings to Plan Review after comments received. Please replace previous complete drawing set with the complete set provided in the project folder provided by Catawba County. Note any clouded revisions on the drawings and consider these revisions part of the base bid being provided and the ultimate responsibility of the GC.

J. Stan Winstead, AIA  
Winstead Architecture, PLLC

**PLEASE ATTACH THIS ADDENDUM TO THE FRONT COVER OF THE SPECIFICATIONS AND ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID.**