



BIDDING ADDENDUM NO. 2
CATAWBA COUNTY CATTLEMEN'S ASSOCIATION
EDUCATION CENTER
NEWTON, NORTH CAROLINA
CBSA Project 2024.008
August 25, 2026

(Applying to all bidders according to classification headings listed below.)

This addendum is issued for the purpose of clarifying the intent of the contract documents for making necessary corrections, deletions, and/or additions to the documents on all items of discrepancy raised up to the time of the issuance of this addendum.

Each bidder is hereby instructed and authorized to incorporate into his proposal the instructions contained in this addendum.

TO ALL BIDDERS

DRAWINGS

SHEET E1 DETAILED ELECTRICAL SPECIFICATIONS - RACEWAYS

1. For clarification, Schedule 40 PVC is acceptable for underground and under slab installations except as noted on Electrical Site Plan to be Schedule 80 PVC under driveway. EMT is acceptable for above grade applications.

This addendum is issued VIA Email to all bidders and to Owner on August 25, 2026 to post so that it can be downloaded at no charge from the following designated Catawba County website:
<https://www.catawbacountync.gov/county-services/purchasing/bid-notice/>

CBSA ARCHITECTS

BY: Marty A. Beal, AIA, LEED AP BD+C

cc. All Bidders
Catawba County