



J. Stan Winstead, AIA

22 North Main Ave., p.o. box 321  
Newton, North Carolina 28658

Telephone: (828) 464-2827  
Fax: (828) 464-3229

## ADDENDUM #2

### Catawba County

### Catawba County EMS Base Station – Hickory, NC

### Bid Number #25-1015

Hickory, North Carolina

December 30, 2024

Applying to all bidders.

This addendum is issued for the purpose of clarifying the intent of the contract documents for making necessary corrections, deletions, and/or additions to the documents on all items of discrepancy raised up to the time of the issuance of this addendum.

Each bidder is hereby instructed and authorized to incorporate into his proposal the instructions contained in this addendum.

## TO ALL BIDDERS

### 1. A Revised Bid Opening Date:

Bid opening date for this project is now being pushed out to **February 13, 2025**. A mandatory pre-bid conference was held on December 18<sup>th</sup>, 2024 on the site at 3:00 pm. You must have had a representative of your company there to be eligible to bid this project. The new opening details are as follows:

Catawba County will receive sealed bids for the construction of a new Catawba County EMS Base Station, Bid Number 25-1015, in the 2nd Floor Meeting Room, Government Center, 25 Government Drive, Newton, North Carolina, 28658 until **3:00 PM, local prevailing time, on February 13, 2025**. The clock/Apple phone in the Government Center, 2nd Floor Meeting Room will be used to determine bid submission closure. Bids received after **3:00 PM on February 13, 2025**, will not be accepted. Immediately thereafter bids shall be publicly opened and read by the Architect for furnishing of labor, materials, and equipment for the construction of the new Catawba County EMS Base Station - Hickory. The project location is 827 E Ave SE, Hickory, North Carolina 28602.

### 2. A Revised Due Date for Contractor Questions:

Questions regarding the Scope of Work, bid process or bid documents must be delivered in writing to Stan Winstead in the office of the Architect, Post Office Box 321, Newton, North Carolina 28658, Phone (828) 464-2827, Fax (828) 464-3229, Email winarch@bellsouth.net no later than 4:00 PM. Eastern Time, on **January 29, 2025**. All questions received before the



J. Stan Winstead, AIA

22 North Main Ave., p.o. box 321  
Newton, North Carolina 28658

Telephone: (828) 464-2827  
Fax: (828) 464-3229

deadline will be addressed in an Addendum. Any questions received after the deadline will not be addressed prior to the Bid Opening. Do not contact the owner with questions.

3. On page A2.0, Window Schedule. Windows A, B, C, D, E should all read Kawneer (or equal) frames 451T, Thermal 2"x4-1/2".
4. On page A2. Door Schedule. Frame #7 is interior, therefore frame should be Kawneer (or equal) 451 Non-thermal, and glass is 1/4" tempered clear glass.

A handwritten signature in black ink that reads "J. Stan Winstead". The signature is written in a cursive, flowing style.

J. Stan Winstead, AIA  
Winstead Architecture, PLLC

**PLEASE ATTACH THIS ADDENDUM TO THE FRONT COVER OF THE SPECIFICATIONS AND ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID.**